

Sarne Duct Filter Replacement Filter

The electret filter fabric used in the Sarne duct filter captures pollen, mold spores, and even very fine airborne pollutant particles. The material collects particles from the air passing through the filter using an electric charge in the fibers of the fabric. Thanks to this, the filter can have a loose structure despite its efficiency, allowing fresh air to flow in easily.

The filter must be replaced once it darkens due to accumulated dust. In urban environments, the filter should be replaced at least every six months. Along busy streets, especially in lower-floor apartments, it is recommended to replace the filter more frequently.

Filter replacement instructions:

1. Remove the wall-mounted air inlet valve or air diffuser.
2. Compress the metal filter frame by squeezing the wires together to reduce its size, and pull the frame out.
3. Remove the old filter and place the new filter onto the wire frame.
4. If the filter does not fit at full size, fold the top of the filter inward into the frame.
5. Note: Do not flip the filter over like with the Velco valve filter.
6. Push the filter back into the duct.

Allergia- ja Sisäilma-apu Oy
Sturenkatu 43, 00550 Helsinki
Finland
www.sarnepro.com

